

July 9, 2013

ADDENDUM NO. #3
Jefferson County Public Works
Vehicle Maintenance Facility

This addendum forms a part of the bidding and contract documents and modifies the bidding documents. Acknowledge receipt of this addendum in space provided on Bid Form. **FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.**

Questions Submitted:

Q1: Can a BP-1 plant mix asphalt be supplied and installed in accordance with Section 401 of the Missouri Standard Specifications for Highway Construction, hand placed in a single lift and compacted as provided in said Section 401 for the pavement over the new utility trenches?

A1: *Yes, this will be an acceptable alternative to the pavement mixture and placement methods previously specified in the project manual and Addendum #2. Density requirements and testing shall be modified appropriately in accordance with Section 401.*

Addendum #3 consists of 1 page of text:

RETURN ONE SIGNED COPY TOGETHER WITH YOUR PROPOSAL

Addendum No.3 is hereby acknowledged.

Name of Bidder: _____

By: _____ Title: _____

Address: _____

Telephone: _____ Date: _____