

| FIRE SUPPRESSION<br>SYSTEMS 2017<br>1-24-17  | FIRE SAFETY INC                                   | PROCON FIRE &<br>SAFETY  |
|--|---|--|
|  | PO BOX 19<br>1 HELMKAMP DR<br>WOOD RIVER IL 62095 | 7 WORTHINGTON ACCESS<br>MARYLAND HEIGHTS MO<br>63043                                   |
| LOCATION 1 JEFFERSON COUNTY<br>COURTHOUSE BASEMENT<br>300 MAIN ST HILLSBORO MO 63050   | YES   |  |
| JEFFERSON COUNTY DATA<br>COMMUNICATIONS ROOM 300 MAIN<br>ST HILLSBORO, MO 63050  | YES   |  |
| THERE IS AN A/C UNIT IN THE ROOM   | YES   | CONTACTS WILL BE<br>PROVIDED FOR<br>CONNECTION BY<br>OTHERS                            |
| MUST TIE INTO THE EXSISTING FIRE<br>ALARM SYSTEM   | NOT INCLUDED                                      | CONTACTS WILL BE<br>PROVIDED FOR<br>CONNECTION BY<br>BUILDING FIRE ALARM<br>CONTRACTOR |
| LOCATION 2 JEFFERSON COUNTY<br>ADMINISTRATIVE BULDING<br>729 MAPLE ST HILLSBORO MO<br>63050  | YES   |  |
| THERE IS NOT A HVAC UNIT IN THE<br>ROOM  |   |  |
| MUST TIE INTO THE EXSISTING FIRE<br>ALARM SYSTEM   | NOT INCLUDED                                      | CONTACTS WILL BE<br>PROVIDED FOR<br>CONNECTION BY<br>BUILDING FIRE ALARM<br>CONTRACTOR |
| LOCATION 3 JEFFERSON COUNTY<br>DR SITE 1403 HERCULANEUM MO<br>63048  | YES   |  |
| THERE IS A SEPARATE HVAC UNIT<br>IN THE ROOM   | OK  | CONTACTS WILL BE<br>PROVIDED FOR<br>CONNECTION BY<br>OTHERS                            |
| THERE IS NO FIRE ALAM SYSTEM IN<br>THE BUILDING.<br>THIS SYSTEM WILL NEED TO HAVE<br>AUTO DIALER TO CALL OUR<br>EXSISTING FIRE ALARM<br>MONITORING COMPANY                                 | DIALER IS INCLUDED,<br>NEED PHONE LINES           |  |
| SYSTEM SPECIFICATIONS  |   |  |
| I AM REQUESTING A STAT - X<br>AEROSOL BASED SYSTEM   | OK  |  |
| THE SYSTEM MUST HAVE AN<br>AUDIBLE ALARM AS WELL AS A<br>VISUAL ALARM  | OK  |  |
| THE SYSTEM SHALL PROVIDE<br>BATTERY BACK-UP POWER,<br>SUFFCIENT TO AUTOMATICALLY<br>SUPPORT THE FULL OPERATION OF<br>THE SYSTEM FOR 24 HOURS IN THE<br>EVENT OF A PRIMARY POWER<br>FAILURE | OK  |  |

| <b>FIRE SUPPRESSION<br/>SYSTEMS 2017<br/>1-24-17</b>   | <b>FIRE SAFETY INC</b>   | <b>PROCON FIRE &amp;<br/>SAFETY</b>   |
|--|--|---|
|  | PO BOX 19<br>1 HELMKAMP DR<br>WOOD RIVER IL 62095                        | 7 WORTHINGTON ACCESS<br>MARYLAND HEIGHTS MO<br>63043  |
| <b>INSTALLATION</b>  |  |   |
| INSTALLATION SHALL BE DONE<br>DURING NORMAL WORKING HOURS<br>(MONDAY-FRIDAY 8:00 AM TO 4:00<br>PM)   | OK   |   |
| THE CONNECTION INTO THE<br>EXISTING FIRE ALARM SYSTEM IN<br>THE COURTHOUSE AND THE<br>ADMINISTRATION BUILDING WILL<br>BE INCLUDED IN THE PRICE | NOT INCLUDED - THE<br>CONTROL PANEL WILL<br>BE PROVIDED WITH<br>CONTACTS | WE WILL PROVIDE<br>CONTACTS FOR<br>CONNECTION<br>BUILDING FIRE ALARM<br>CONTRACTOR. COST<br>OF CONTRACTOR TO<br>BE PAID BY JEFFCO |
| ALL BUILDING PERMITS WILL BE<br>RESPONSIBILITY OF THE VENDOR   | OK   |   |
| ALL INSPECTIONS BY THE BUILDING<br>INSPECTOR AND THE FIRE<br>MARSHALL WILL BE THE<br>RESPONSIBILITY OF THE VENDOR                              | OK   |   |
| <b>MAINTENANCE</b>   |  |   |
| THE SYSTEM SHOULD BE<br>INSPECTED BY THE VENDOR YEAR<br>EVERY YEAR.  | FIRST YEAR<br>INSPECTION IS<br>INCLUDED                                  |   |
| PLEASE INCLUDE ANY ON-GOING<br>ANNUAL MAINTENANCE COSTS IF<br>THERE ARE ANY  | ANNUAL INSPECTIONS<br>ARE REQUIRED FIRST<br>YEAR INCLUDED                | \$170 PER INSPECTION<br>PER SYSTEM, IF ALL 4<br>INSPECTED   |
| PLEASE INCLUDE REPLACEMENT<br>FEES IF THE SYSTEM SHOULD BE<br>USED   | 1. \$3700<br>2. \$3900<br>3. \$1500                                      | \$650 PER AESOSOL<br>GENERATOR PLUS \$16<br>PER E-MATCH (1 FOR<br>EACH GENERATOR) +<br>LABOR @ \$85 PER HOUR                      |
| <b>MISCELLANEOUS</b>   |  |   |
| I AM EXPECTING ALL VENDORS<br>RESPONDING TO THIS RFP TO<br>SCHEDULE A TIME WITH<br>INFORMATION TECHNOLOGY TO<br>VISIT THE LOCATION             | DONE   |   |
| I WILL NEED A FIRE SUPPRESSION<br>SYSTEM RECORD OF COMPLETION<br>INITIAL INSPECTION AND<br>ACCEPTANCE TEST UPON<br>COMPLETION OF EACH LOCATION | INCLUDED   |   |
| TRAINING OF THE IT STAFF AND<br>FACILITIES MUST BE INCLUDED  | INCLUDED   |   |
| TOTAL PROPOSED COST OF THE<br>FIRE SUPPRESSION SYSTEM  | \$32,550.00  | \$34,877.00   |

| <b>FIRE SUPPRESSION<br/>SYSTEMS 2017<br/>1-24-17</b>   | <b>FIRE SAFETY INC</b>                            | <b>PROCON FIRE &amp;<br/>SAFETY</b>                  |
|--|---|--|
|  | PO BOX 19<br>1 HELMKAMP DR<br>WOOD RIVER IL 62095 | 7 WORTHINGTON ACCESS<br>MARYLAND HEIGHTS MO<br>63043 |
| <b>REQUIRED DOCUMENTS</b>  |   |  |
| NOTARIZED WORK AFFIDAVIT<br>COMPLETED  | Y   | N  |
| E-VERIFICATION DOCUMENTATION<br>(Y/N):   | Y   | N  |
| COPY OF INSURANCE PROVIDED   | Y   | Y  |
| TAX RECEIPTS OR NOTARIZED<br>LETTER STATING NO REAL OR<br>PERSONAL PROPERTY OWNED IN<br>JEFFERSON COUNTY | Y   | Y  |
| COOPERATIVE BID FORM (Y/N)   | Y   | Y  |
| COOPERATIVE CONTACT INFO:  | Y   | Y  |
| COMPANY INFORMATION AND<br>SIGNATURE   | Y   | Y  |
| BID DEPOSIT REQUIRED   | N/A   | N/A  |
| <b>COMMENTS:</b>   |   | PAGES 9 AND 10 ARE<br>NOT FILLED OUT                 |